



**Office of the Fire Marshal**

**Tent Permit Request**

Submission Date \_\_\_\_\_

Event: \_\_\_\_\_

Event Date: \_\_\_\_\_

Location: \_\_\_\_\_

Time: \_\_\_\_\_

Sponsored by: \_\_\_\_\_

Request Submitted by: \_\_\_\_\_

Contact # \_\_\_\_\_

Email: \_\_\_\_\_

***According to the International Fire Code and the University of South Alabama's guidelines, all tents and canopies must be permitted. This applies to all tents larger than 12 x 12, or over 400 sq. ft.***

**Tent Size(s)** \_\_\_\_\_

Is a Dig Permit required as per USAs Tent Guidelines for this tent? (If tent stakes utilized)

Yes\_\_\_ No\_\_\_

Additional Comments

---

---

---

## Commercial

***The information provided in this section(s) is for your use and will be completed by the AHJ prior to the event.***

\_\_\_ A Certificate of Flame Resistant or other approval by testing as evidence of the required fire resistance. Tent and canopy must be erected in accordance with manufacturer recommendations, industry standards, and code requirements.

\_\_\_ Tents with sides attached with capability of being enclosed must meet these requirements even if it is intended to remain open during the event.

\_\_\_ Exits are based on the occupancy capacity and must have a minimum width of 36 inches and the exit height of not less than 7 feet. Guy ropes must not cross an exit. Occupant Load of 10-199 shall have 2 means of egress.

\_\_\_ Tents or membrane structure shall not be located within 10 feet of lot lines, buildings or tents or membrane structures, parked vehicles or internal combustion engines.

\_\_\_ Open flame cooking within a tent is prohibited.

\_\_\_ When multiple tents are used, an unobstructed fire break passageway not less than 10 ft. wide and free from guy ropes and obstructions shall be maintained on all sides of all tents.

\_\_\_ Fire extinguisher (dry chemical, ABC) is required and shall be mounted as to be easily seen.

\_\_\_ Smoking is prohibited in any campus environment.

\_\_\_ Any electrical components utilized within the tent is subject to approval by the Fire Marshal and/or the department of Safety and Environmental Compliance.

\_\_\_ Wind/weather conditions shall be monitored the day of the event. Rating of the structure per the manufacturer.



Safety and Environmental Compliance / Fire Marshal

600 Clinic Drive, Mobile, Alabama 36688

251-460-7070